

EDGESlot Batwing 65°

ESL4

Light efficiency:

111 Lumen/Watt**Output: 1388 lm**




Light quality:

CRI: 92.6**Peak: 432 cd**

Color temperature:

2965 K**Power: 12.5 W****PF: 1.0**

No photo



Product name:

EDGESlot Batwing 65°

Item number:

ESL4

Configuration:

ESL4-4FT-3590-AL-DB65-350LPF



Date and time:

11/8/2021 3:21:34 PM


Description:

Power Supply @ 410mA


Color Details



TM-30: 88.6



CRI: 92.6 (R1-R8)



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
93.4	98.3	98.0	90.7	92.4	96.8	90.2	81.0	59.8	94.5	91.6	76.9	95.0	99.8	88.8


TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
87.8	91.8	93.5	88.9	92.4	93.4	85.1	91.0	85.7	82.7	86.2	90.1	90.0	86.8	88.5	83.2

CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
85.6	93.7	90.8	86.4	86.8	88.1	91.7	93.8	96.0	95.8	94.9	93.8	92.8	87.3	87.3

CQS: 90.2



Color parameters

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
2965 K	92.6	59.8	88.6	95.2	90.2	0.441	0.407	0.252	0.349	0.0006

TM-30 Details







Rf 88.6

Fidelity index Rf

Rg 95.2

Gamut index Rg


Hue Bin	R _f	Shifts (%)	
		Chroma	Hue
1	88	-5%	2%
2	92	-3%	2%
3	93	-2%	2%
4	89	-6%	-3%
5	92	-6%	0%
6	93	-4%	0%
7	85	-8%	5%
8	91	-3%	5%
9	86	-2%	9%
10	83	1%	12%
11	86	5%	9%
12	90	6%	-1%
13	90	0%	-8%
14	87	2%	-10%
15	89	-5%	-1%
16	83	-4%	-12%



EDGESlot Batwing 65°

ESL4

Beam details



Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3.3ft	6.6ft	9.8ft	13.1ft	16.4ft	19.7ft	23ft	26.2ft	29.5ft	32.8ft	36.1ft	39.4ft	42.7ft	45.9ft	49.2ft	52.5ft	55.8ft	59.1ft	62.3ft	65.6ft
374lx	94lx	42lx	23lx	15lx	10lx	8lx	6lx	5lx	4lx	3lx	3lx	2lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx
34.8fc	8.7fcd	3.9fcd	2.2fcd	1.4fcd	1fcd	0.7fcd	0.5fcd	0.4fcd	0.3fcd	0.3fcd	0.2fcd	0.2fcd	0.2fcd	0.2fcd	0.1fcd	0.1fcd	0.1fcd	0.1fcd	0.1fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
374	371	366	357	346	331	314	295	274	251	226	199	169	138	106	74	43	17	7	6
100%	99%	98%	96%	92%	89%	84%	79%	73%	67%	60%	53%	45%	37%	28%	20%	11%	5%	2%	2%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
374	379	391	406	421	430	430	421	404	379	348	310	266	218	168	117	71	31	16	15
100%	101%	104%	109%	112%	115%	115%	113%	108%	101%	93%	83%	71%	58%	45%	31%	19%	8%	4%	4%

Intensities in 180° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
374	371	366	357	346	331	314	295	274	251	226	199	169	138	106	74	43	17	7	6
100%	99%	98%	96%	92%	89%	84%	79%	73%	67%	60%	53%	45%	37%	28%	20%	11%	5%	2%	2%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
374	379	391	406	421	430	430	421	404	379	348	310	266	218	168	117	71	31	16	15
100%	101%	104%	109%	112%	115%	115%	113%	108%	101%	93%	83%	71%	58%	45%	31%	19%	8%	4%	4%

UGR

Glare evaluation according to UGR

p Ceiling		70	70	50	50	30	70	70	50	50	30
p Walls		50	30	50	30	30	50	30	50	30	30
p Floor		20	20	20	20	20	20	20	20	20	20
Room size X Y		Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
2H	2H	16.4	17.7	16.7	18.0	18.3	18.6	19.8	18.8	20.2	20.4
	3H	17.8	19.1	18.2	19.4	19.6	20.2	21.5	20.6	21.8	22.0
	4H	18.4	19.6	18.8	19.9	20.2	20.9	22.1	21.3	22.4	22.7
	6H	18.8	20.0	19.2	20.2	20.6	21.4	22.5	21.7	22.8	23.2
	8H	19.0	20.0	19.3	20.3	20.8	21.6	22.7	21.9	23.0	23.4
	12H	19.0	20.1	19.4	20.4	20.8	21.7	22.7	22.0	23.1	23.5
4H	2H	17.5	18.8	17.9	19.1	19.3	19.1	20.3	19.5	20.6	20.9
	3H	19.2	20.2	19.5	20.5	21.0	21.1	22.1	21.4	22.4	22.9
	4H	19.7	20.7	20.2	21.1	21.7	21.8	22.8	22.2	23.2	23.7
	6H	20.2	21.1	20.7	21.5	21.9	22.4	23.3	22.9	23.7	24.1
	8H	20.4	21.2	20.9	21.6	22.0	22.7	23.5	23.2	23.9	24.2
	12H	20.4	21.2	20.9	21.6	22.1	22.8	23.5	23.3	23.9	24.4
8H	4H	20.2	21.1	20.8	21.5	21.8	22.0	22.9	22.5	23.2	23.6
	6H	20.9	21.5	21.4	22.0	22.5	22.8	23.5	23.3	24.0	24.5
	8H	21.1	21.7	21.6	22.2	22.9	23.2	23.8	23.7	24.3	24.9
	12H	21.3	21.8	21.9	22.3	22.9	23.4	23.9	24.0	24.4	25.0
12H	4H	20.3	21.0	20.8	21.4	21.9	22.0	22.7	22.5	23.2	23.6
	6H	21.0	21.6	21.5	22.1	22.8	22.9	23.5	23.4	24.0	24.6
	8H	21.3	21.8	21.9	22.3	22.9	23.3	23.7	23.8	24.2	24.9
Variation of the observer position for the luminaire distance S											
S = 1.0H		0.1 / -0.1					0.1 / -0.1				
S = 1.5H		0.2 / -0.3					0.1 / -0.2				
S = 2.0H		0.4 / -0.6					0.4 / -0.4				
CIE 117-1995. Corrected glare indices referring to 1388 lm total luminous flux											