






EDGESolo Asymmetric 50° at 25°**ESO275****Light efficiency:****148 Lumen/Watt****Output: 706 lm****Light quality:****CRI: 83.8****Peak: 376 cd****Color temperature:****3906 K****Power: 4.8 W****PF: 1.0**


No photo

**Product name:****EDGESolo Asymmetric 50° at 25°****Item number:****ESO275****Configuration:****ESO275-2FT-4080-WT-DA5025-350LPF****Date and time:****3/29/2022 12:46:16 PM****Description:****Gen 1 LG features out****BW lens features out****Power Supply ma:16**


Color Details




TM-30: 82.8



CRI: 83.8 (R1-R8)



CQS: 82.2



CRI R values, only R1-R8 are used to calculate final CRI value

R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14	R15
82.8	92.4	95.9	79.9	81.7	87.8	85.0	65.3	15.4	80.6	78.3	58.6	85.7	98.4	76.8

TM30 C values, 16 binned values out of total of 99 C values

C1	C2	C3	C4	C5	C6	C7	C8	C9	C10	C11	C12	C13	C14	C15	C16
79.1	83.8	81.9	87.7	88.9	92.8	87.0	85.2	80.5	73.2	76.5	85.0	84.6	86.9	78.9	76.6

CQS Q values

Q1	Q2	Q3	Q4	Q5	Q6	Q7	Q8	Q9	Q10	Q11	Q12	Q13	Q14	Q15
80.5	96.5	80.4	73.4	77.5	80.0	84.1	88.4	97.6	91.2	86.4	84.5	83.8	74.1	76.9

Color parameters

Color temperature	Color rendering index	Red component	Color fidelity	Color gamut	Color quality scale	Color coordinate cie 1931	Color coordinate cie 1931	Color coordinate	Color coordinate	Color deviation from black body
CCT	CRI	CRI R9	TM30 Rf	TM30 Rg	CQS	x	y	u	v	Δuv
3906 K	83.8	15.4	82.8	93.1	82.2	0.385	0.380	0.227	0.336	0.0001

TM-30 Details







Rf 82.8

Fidelity index Rf


Rg 93.1

Gamut index Rg

Hue Bin	R_f	Shifts (%)	
		Chroma	Hue
1	79	-12%	1%
2	84	-7%	6%
3	82	-4%	8%
4	88	-3%	3%
5	89	-5%	1%
6	93	-3%	-2%
7	87	-8%	0%
8	85	-8%	4%
9	80	-7%	13%
10	73	-4%	16%
11	76	5%	16%
12	85	7%	3%
13	85	6%	-9%
14	87	7%	-9%
15	79	-3%	-13%
16	77	-7%	-11%



Beam details



Beam intensities from 1-20m

1m	2m	3m	4m	5m	6m	7m	8m	9m	10m	11m	12m	13m	14m	15m	16m	17m	18m	19m	20m
3.3ft	6.6ft	9.8ft	13.1ft	16.4ft	19.7ft	23ft	26.2ft	29.5ft	32.8ft	36.1ft	39.4ft	42.7ft	45.9ft	49.2ft	52.5ft	55.8ft	59.1ft	62.3ft	65.6ft
291lx	73lx	32lx	18lx	12lx	8lx	6lx	5lx	4lx	3lx	2lx	2lx	2lx	1lx	1lx	1lx	1lx	1lx	1lx	1lx
27.1fcd	6.8fcd	3fcd	1.7fcd	1.1fcd	0.8fcd	0.6fcd	0.4fcd	0.3fcd	0.3fcd	0.2fcd	0.2fcd	0.2fcd	0.1fcd	0.1fcd	0.1fcd	0.1fcd	0.1fcd	0.1fcd	0.1fcd

Intensities in 0° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
291	294	292	288	282	272	259	240	215	185	153	122	96	73	54	38	24	12	5	3
100%	101%	100%	99%	97%	93%	89%	82%	74%	64%	53%	42%	33%	25%	19%	13%	8%	4%	2%	1%

Intensities in 90° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
291	313	337	361	376	368	328	263	196	148	123	108	95	79	55	24	8	4	4	4
100%	107%	116%	124%	129%	126%	113%	90%	67%	51%	42%	37%	33%	27%	19%	8%	3%	1%	1%	1%

Intensities in 180° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
291	294	292	288	282	272	259	240	215	185	153	122	96	73	54	38	24	12	5	3
100%	101%	100%	99%	97%	93%	89%	82%	74%	64%	53%	42%	33%	25%	19%	13%	8%	4%	2%	1%

Intensities in 270° c-plane

0°	5°	10°	15°	20°	25°	30°	35°	40°	45°	50°	55°	60°	65°	70°	75°	80°	85°	90°	95°
291	272	254	234	213	189	165	139	114	90	72	62	56	52	47	39	29	17	8	3
100%	93%	87%	80%	73%	65%	56%	48%	39%	31%	25%	21%	19%	18%	16%	13%	10%	6%	3%	1%

UGR

Glare evaluation according to UGR

p Ceiling	70	70	50	50	30	70	70	50	50	30
p Walls	50	30	50	30	30	50	30	50	30	30
p Floor	20	20	20	20	20	20	20	20	20	20
Room size X Y	Viewing direction at right angles to lamp axis					Viewing direction parallel to lamp axis				
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a	n/a
Variation of the observer position for the luminaire distance S										
n/a	n/a					n/a				
n/a	n/a					n/a				
n/a	n/a					n/a				
CIE 117-1995. Corrected glare indices referring to 706 lm total luminous flux										